

## INVITATION TO TENDER CS 02-08

### CANOE VALLEY RECREATION CENTRE ELECTRICAL FOR FITNESS AREA ADDITION

#### ADDENDUM NO. 1

1. All outlets and switches to be “Décor” type and covers to be stainless steel.
2. Change smoke detector to heat detector. Wire guard to be installed by Regional District staff at a later date.
3. Disregard notes 5. and 6. under lighting heading.
4. Disregard “new location for existing fire gong”, the fire gong will be relocated directly above the existing location, minimum 2’ – 0” above the finished interior room roof. Regional staff will install a protective cage over the gong at a later date.
5. Light fixture to be surface mount florescent Luminaire with 120V electronic ballast, vandal resistant lens and 2 – F32T8 3500K lamps. Catalogue numbers: Peerless Electric Cat. #VR-232-120EL  
Kenall Lighting Cat. #R548-2-32-eb1 – 120 – WHT  
Columbia Cat. #VL-4-232-EBB-120-WL
6. Ceiling mounted exhaust fans are to be changed to one centrally located wall mounted, 100 CFM fan complete with grill and back-draft damper. Fan to be controlled by Humidistat on timer switch. Type and make to match existing fan installed in change room 6. To verify make and model of existing fan, contact Rob Ellement, Recreation Facilities Manager of the Canoe Valley Recreation Centre.