



Addendum No. 2

Invitation to Tender – ES-11-05

Chain Link Fence Installation - Foothills Boulevard Regional Landfill

The addendum is being issued prior to the closing of the tenders to provide further information, make changes to, or to clarify the Contract Documents and is to be read, interpreted and coordinated with all other parts of the Contract Documents. In the case of a conflict with the balance of the documents, this Addendum shall govern. **Tenderers shall acknowledge receipt of this Addendum on the Tender Form and shall attach a signed copy of this addendum to their Tender.**

This addendum shall form part of the Contract Documents.

Question:

Item 4., Bullet 5 of the Scope of Work section of Tender ES-11-05 states “Do not install fence fabric until post hole concrete has cured”, which based on the concrete being specified at 20 MPa – minimum 28 days.

In essence this would mean we would install all of the posts and then not return to the site for a minimum of 28 days to complete the fence work. This is neither practical or fence industry standard procedure.

Please confirm that it will be acceptable to proceed with completion of the fence work as soon as the posts have been installed and not 28 days later.

Response:

Yes. That refers to building code requirements on the concrete curing. In all practicality of industry standards you can start installing once hardened in 24 hours.

Date: May 25, 2011

Addendum 2 Received.

Signature of Tenderer

Name of Tenderer