



**INVITATION TO TENDER PS 01-08**

**SALMON VALLEY FIRE HALL  
BUILDING ADDITION AND RENOVATIONS**

**ADDENDUM NO. 3**

**Question:** Do you happen to know where the gas service enters the building and if it is propane or natural gas? We are not sure if the gas line that feeds the existing heater is large enough to support the new heater so we may have to run a new line from the meter; do you know if the existing meter is sized for the additional heater?

**Answer:** Terasen Gas provided this information. The existing meter is a 200 series with a capacity of 300,000 BTU. The natural gas service line from the main line to the building is ½". The natural gas meter is located 5'-5" in from the north corner of the west side of the building.

The mean temperature in the new addition and existing bay areas is required to be between 10 dag C. to 18 dag C. At no time can the temperature in these areas drop below freezing.