



**ITT CS 14-02**  
**Tete Jaune Community Hall Improvements**

**ADDENDUM No. 1**

---

1. During the May 15, 2014 mandatory site meeting, specifications for flooring, exterior lights, washroom partitions, and railings were requested. Those specifications are as follows:

- a) Linoleum Specifications:

Linoleum is to meet or exceed Armstrong Connection Corlon (colour: porcelain or desert sand).

- b) Washroom Partition Specifications:

Washroom partitions are to be floor-mounted, overhead braced, powder-coated metal partitions (colour: light grey)

- c) Exterior Lighting Specifications:

Exterior Lighting is to meet or exceed Cooper Lighting by Eaton – Halo 4" Surface LED Downlight ID #SLD405830WH.

- d) Railing Specifications:

Railing system is to meet or exceed PEAK aluminum railing – standard pickets (colour: white)

**Substitutions must be approved by the Regional District.**

2. The Regional District is responsible for deck finish.
3. Windows are to be white vinyl.

Please direct all questions to the project manager:

Hank Hanson, Project Manager  
Regional District of Fraser-Fort George  
Telephone: 250-960-4460  
Fax: 250-562-8676  
Email: [hhanson@rdffg.bc.ca](mailto:hhanson@rdffg.bc.ca)