



ADDENDUM No. 1

**Invitation to Quote CS-16-06
Canoe Valley Recreation Centre Exercise Room Ventilation Project**

The addendum is being issued prior to the closing of the Quote to provide further information, make changes to, or to clarify the Contract Documents and is to be read, interpreted and coordinated with all other parts of the Contract Documents. In the case of a conflict with the balance of the documents, this Addendum shall govern. **Bidders shall acknowledge receipt of this Addendum on the Quote Form and shall attach a signed copy of this addendum to their Quote.** This addendum shall form part of the Contract Documents.

Change to SCOPE OF WORK - (page 14):

To be added:

“The area to be cooled is 740 sq. ft. A 18,000 BTU (1.5 ton) system should give adequate air conditioning. The condenser unit is mounted on the roof, on the access platform near the north wall. The evaporator coil is sized to match the condenser (1.5 ton), and would be mounted inside the exercise room at the middle of the interior end wall near the electrical panel. Heating is supplied by the existing baseboard heaters, a 230 volt system with a higher efficiency rating. This system does not require ductwork. A suitable unit would be the Frigidaire model FHP182SQ2 or an equivalent model.”

All inquiries related to this Invitation to Quote must be directed to:

Lyle Lewis, Facilities Manager
Phone: 250-569-3360
Fax: 250-569-3337
Email: llewis@rdffg.bc.ca