



July 27, 2016

ADDENDUM No. 1

**Request for Proposal CS-16-09
Electrical Equipment Purchase for Auxiliary Power Supply**

*The addendum is being issued prior to the closing of the request for proposal to provide further information, make changes to, or to clarify the Contract Documents and is to be read, interpreted and coordinated with all other parts of the Contract Documents. In the case of a conflict with the balance of the documents, this Addendum shall govern. **Bidders shall attach a signed copy of this addendum to their Proposal.** This addendum shall form part of the Contract Documents.*

Question #1: Is the temperature rise of 130 degrees acceptable for a standby rating?

Answer: The use of the 130 degree C temperature rise will be acceptable.

Question #2: ATS page 37 shows a 600 amp and page 43 shows an 800 amp?

Answer: The ATS will be 800A.

Question #3: What size Main Breaker is to be on the generator?

Answer: Main Breaker on the generator is to be 250A, 3P.

Question #4: Is a PDF submission via email acceptable?

Answer: Submissions are to be compliant with our review process, five hard copies of the proposal are requested. Email submissions will not be accepted as stated in the RFP.

Proposals must be sent to:

General Manager of Financial Services
Regional District of Fraser-Fort George
3rd Floor, 155 George Street
Prince George BC V2L 1P8

Questions relating to RFP CS-16-08 must be directed to:

Michael Higgins, Emergency Services Coordinator
Regional District of Fraser-Fort George
155 George Street
Prince George BC V2L 1P8
Telephone: 250-960-4400 / 1-800-667-1959
Fax: 250-562-8676
Email: mhiggins@rdffg.bc.ca

Questions relating to the Project must be directed to:

Lane R.J. Logan, P. Eng.
Sr. Electrical Engineer/Division Manager
McElhanney Consulting Services Ltd.
12- 556 North Nechako Road
Prince George BC V2K 1A1
Telephone: 778-693-2192
Fax: N/A
Email: llogan@mcelhanney.com