



March 23, 2017

ADDENDUM No. 1

**Invitation to Tender CS-17-03
ROBSON VALLEY RECREATION CENTRE
INTERCONNECT HEAT TRANSFER SYSTEM**

*The addendum is being issued prior to the closing of the Invitation to Tender (ITT) to provide further information, make changes to, or to clarify the ITT Documents and is to be read, interpreted and coordinated with all other parts of the ITT Documents. In the case of a conflict with the balance of the documents, this Addendum shall govern. **Bidders shall attach a signed copy of this addendum to their tender submission, failure to do so may result in a non-compliant bid.** This addendum shall form part of the Contract Documents.*

APPENDIX B – SCOPE OF WORK

Has been amended to include the following items:

- g. Contractor must supply pictures of all underground works in the utility corridor, prior to backfilling.
- h. Regional District will relocate the Sea Can to a location that will not impact the ground works.
- i. Trace wire is required in the same trench as the heating lines and just above the lines.

APPENDIX C - DRAWINGS

Robson Valley Recreation Centre

2017 Heat Recovery Connection to Community Centre – Buried Piping

Clarification to Section 4 EXECUTION, clause 4.12 remains unchanged and is as stated in the ITT.

I/We hereby verify that we have considered this addendum in our bid submission.

Bidder Signature

Date

All inquiries relating to this ITT must be directed to:

Lyle Lewis, Project Manager
Email: llewis@rdffg.bc.ca
Phone: 250-569-7590
Fax: 250-569-3337