



October 22, 2020

ADDENDUM No. 1

**Invitation to Quote CS-20-17
SUPPLY OF SCOTT CARBON FIBER SCBA AIR CYLINDERS**

*The addendum is being issued prior to the closing of the invitation to quote (ITQ) to provide further information, make changes to, or to clarify the ITQ documents and is to be read, interpreted and coordinated with all other parts of the ITQ documents. In the case of a conflict with the balance of the documents, this Addendum shall govern. **Bidders shall attach a signed copy of this addendum to their quote submission, failure to do so may result in a non-compliant quotation.***

This addendum is being provided in clarification to ITQ CS-20-17 released October 13, 2020.

QUESTION 1: Are these CGA style cylinders or snap change style cylinders?

ANSWER 1: SCBA cylinders are to be the CGA style.

I/We hereby verify that we have considered this addendum in our proposal submission.

Proponent's Signature

Date

All inquiries relating to ITQ CS-20-17 must be emailed to:
Bonnie Seitz, Community/Public Safety Assistant
bseitz@rdffg.bc.ca