



Addendum No. 3

Request for Proposals ES-20-01 Emergency Response Plans for Solid Waste Facilities

The addendum is being issued prior to the closing of the Request for Proposals to provide further information, make changes to, or to clarify the Contract Documents and is to be read, interpreted and coordinated with all other parts of the Contract Documents. In the case of a conflict with the balance of the documents, this Addendum shall govern. **Proponents shall attach a signed copy of this addendum to their proposal.** This addendum shall form part of the Contract Documents.

Question #1: How many buildings in total are on all sites?

Answer: There are 15 buildings and or structures in total. This includes a total of ten (10) buildings or structures at the Foothills Boulevard Regional Landfill and a total of five (5) buildings or structures at the Mackenzie Regional Transfer Station and Mackenzie Demolition and Construction Landfill. For the purpose of this RFP a building is defined as follows;

Under the **BC Building Code 2018** and **BC Fire Code 2018** a building is defined as: any structure used or intended for supporting or sheltering any use or occupancy. Further, the **BC Building Code 2018** does not apply to accessory buildings less than 10 m² in building area that do not create a hazard. It should also be noted that **WorkSafeBC OHS 4.1 Safe workplace** states: A workplace must be planned, constructed, used and maintained to protect from danger any person working at the work place. **OHS 4.2 Safe buildings and structures:** The employer must ensure that each building and temporary or permanent structure in a workplace is capable of withstanding any stresses likely to be imposed on it.

Foothills Boulevard Regional Landfill: 10

- Scale house
- Office trailer
- Staff lunchroom/locker room trailer
- Fuel shed
- Tool storage shed
- Oil/antifreeze lean-to
- Landfill gas blower building and shop
- Large storage shed
- Large storage lean-to
- Contractor container

Mackenzie Regional Transfer Station and Mackenzie Demolition and Construction Landfill: 5

- New scale house
- Old scale house
- Swap shed
- Staff lunchroom/locker room trailer
- Waste tipping building

The Regional District of Fraser-Fort George does not expect the same Emergency Response Plans, Fire Safety Plans and ensuing procedures for all buildings. Based on their size and purpose, each building will have different requirements.

Date: February 5, 2020

Addendum No. 3 Received.

Signature of Proponent

Name of Proponent

Inquiries relating to this RFP may be directed to:

Darwin Paton, Environmental Services Technician
Regional District of Fraser-Fort George
155 George Street, Prince George, BC V2L 1P8
Phone: 250-960-4400 / Fax: 250-562-8676
Email: dpaton@rdffg.bc.ca